

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 972/D/SWA/NSA

Dated: 04/02/2026

It is certified that an inspection team headed by ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the ALLENHOUSE PUBLIC SCHOOL 804-B-Block Parki Kanpur

(Name & Address of the school) on 19/1/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 405/SWA/CHEM dated 27/1/2026

of PUBLIC HEALTH LABORATORY KANPUR (PHED Lab) certified that the

ALLENHOUSE PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal

Name

Designation

Name & Address of the Office / Department :

Signature: *[Handwritten Signature]*
Name: *[Handwritten Name]*
Designation: *[Handwritten Designation]*
Name & Address of the Office / Department: *[Handwritten Address]*

Do: Ajay Kumar Shankhwar
N.S.A.

To Allenhouse Public School 804-B-Block

Parki Kanpur Nagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the ^{W/S} Allenhouse Public School, 884 B-Block

Sample taken from — — — Submersible' Panki, Kanpur

Date of sample Drawn — — — 19/1/2026 — — —

Date of analysis — — — 19/1/2026 — — —

Physical Character — — — Transparent / Odourless — — —

P. H. Value — — — 8.46 — — —

Free Ammonia Parts per 1000000 — — — Nil — — —

Albuminoid Ammonia Part per 1000000 — — — Nil — — —

Oxygen absorbed from pot. Permanganate
in three hours at 37° C — — — 0.00 — — —

Chloride Part per 1000000 — — — 14.00 — — —

Nitrates Parts per 1000000 — — — Nil — — —

Nitrates Parts per 1000000 — — — Nil — — —

Total solid part per 100000 — — — 370.00 — — —

Fixed solid Parts per 1000000 — — — 340.00 — — —

Volatils solid Parts per 100000 — — — 30.00 — — —

Appearance on ignition — — — No Charring — — —

Total hardness Parts per 1000000 — — — 212.00 — — —

Permanent hardness Parts per 1000000 — — — 176.00 — — —

Temporary hardness Parts per 1000000 — — — 36.00 — — —

Remarks : POTABLE

No. 405/SWAKHAM dated 27/1/2026

Copy forwarded for favour or information to

W/S
1) Allenhouse Public School
884, B-Block, Panki Kanpur

2) N.S.A. Kanpur Nagar Nigam

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

ALKA SINGH
(Chemist) Nagar Nigam Kanpur



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Allenhouse Public School, 884 B-Block Pandei, Kanpur

Name & designation of the person collecting samples... ALKA SINGH - CHEMIST

D.No. 405/SA/Chem 27/11/2022

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water			Presumptive Coliform count	Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS		
		at 37.°c in 48 hours	at room temp- ratur in 72 hours	Quantity of water put in each tube No of tubes put up						
19/11/2022	Submersible	'22'	'64'	—	50ML. 1	10 ML. 5	1 MI 5	ZERO	Nil	Satisfactory

Remarks: Chlorination is necessary. P.C. would be 0.2 PPM.

Copy for Information Forwarded to (1) W/S Allenhouse Public School, 884 B-Block Pandei Kanpur

(2) N.S.A. Kanpur Nagar Nigam

ALKA SINGH
 (Chemist)
 Nagar Nigam Kanpur

Nagar Sanstha Kanpur
 नगर स्वास्थ्य संस्थान
 नगर निगम कानपुर