

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 1417/D/SWA/NSA

Dated: 18/3/2025

It is certified that an inspection team headed by ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the ALLENHOUSE PUBLIC SCHOOL, PANKI KANPUR NAGAR

(Name & Address of the school) on 03/3/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 353/SWA/chem dated 10/3/2025

of PUBLIC HEALTH LABORATORY KAN (PHED Lab) certified that the

ALLEN HOUSE PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department: नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

To ALLENHOUSE PUBLIC SCHOOL

PANKI, KANPUR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the Allenhouse Public School, Panki Kanpur

Sample taken from	—	—	—	<u>Submersible</u>	—	—	—
Date of sample Drawn	—	—	—	<u>03/3/2025</u>	—	—	—
Date of analysis	—	—	—	<u>04/3/2025</u>	—	—	—
Physical Character	—	—	—	<u>Transparent / Odourless</u>	—	—	—
P. H. Value	—	—	—	<u>7.74</u>	—	—	—
Free Ammonia Parts per 1000000	—	—	—	<u>Nil</u>	—	—	—
Albuminoid Ammonia Part per 1000000	—	—	—	<u>Nil</u>	—	—	—
Oxygen absorbed from pot. Permanganate in three hours at 37° C	—	—	—	<u>0.00</u>	—	—	—
Chloride Part per 1000000	—	—	—	<u>14.00</u>	—	—	—
Nitrites Parts per 1000000	—	—	—	<u>Nil</u>	—	—	—
Nitrates Parts per 1000000	—	—	—	<u>Nil</u>	—	—	—
Total solid part per 100000	—	—	—	<u>400.00</u>	—	—	—
Fixed solid Parts per 1000000	—	—	—	<u>372.00</u>	—	—	—
Volatils solid Parts per 100000	—	—	—	<u>28.00</u>	—	—	—
Appearance on ignition	—	—	—	<u>No Charring</u>	—	—	—
Total hardness Parts per 1000000	—	—	—	<u>246.00</u>	—	—	—
Permanent hardness Parts per 1000000	—	—	—	<u>192.00</u>	—	—	—
Temporary hardness Parts per 1000000	—	—	—	<u>54.00</u>	—	—	—

Remarks :

'POTABLE'

No. 363/Swasthya dated 10/3/2025

Copy forwarded for favour or information to

1) Allenhouse Public School
Panki Kanpur

ALKA SINGH
(Chemist)

Nagar Swasthya Adhikari
Nagari Nigam Kanpur
नगर निगम कानपुर

2) N.S.A. Kanpur Nagar Nigam



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Allenhouse Public School, Panki Kanpur Nagar
 Name & designation of the person collecting samples. ALKA SINGH - CHEMIST

Date & time of collection	Source of sample	Colony count on Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37°C in 48 hours	at room temperature in 72 hours	Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5	1 MI 5			
03/3/2025	Submersible 'Zero' '04'				Nil	Nil	Nil	Zero	Nil	Good

Remark:- Chlorination is necessary / f.r.c. must be 0.2 ppm

Copy for Information Forwarded to (1) Allenhouse Public School Panki Kanpur

(2) N.S.A. Kanpur Nagar Nigam


 Nagar Swasthya Rakshak
ALKA SINGH
 (Chemist) नगर निगम कांपुर
 Nagar Nigam Kanpur