



नगर निगम, लखनऊ

प्रेषक :- सफाई एवं खाद्य निरीक्षक, जोन-4, नगर निगम, लखनऊ।	सेवा में :- Admin Office, Delhi Public School, Sector-4, Gomti Nagar, Ex.-226010 Mo- 9919845041
पत्र सं० - 472/SFI-4/2025 दिनांक 24/6/2025	

प्रमाण-पत्र


दिल्ली पब्लिक स्कूल, सेक्टर-4, गोमती नगर, विस्तार, लखनऊ का निरीक्षण हेल्थ एण्ड सेनीटेशन के दृष्टिकोण से किया गया है।

निरीक्षणोपरान्त दिल्ली पब्लिक स्कूल, सेक्टर-4, गोमती नगर, विस्तार, लखनऊ विद्यालय में कोरिंग एव वॉटर कूलर द्वारा शुद्ध पेयजल की व्यवस्था पायी तथा क्लासरूम एवं शौचालय साफ-सुथरा पाये गये। स्कूल का वातावरण हेल्थ एण्ड हाईजीन के दृष्टि से संतोषजनक पाया गया।

सफाई एवं खाद्य निरीक्षक
जोन-4, नगर निगम, लखनऊ

सफाई एवं खाद्य निरीक्षक
नगर निगम जोन-4, लखनऊ


Manager
Delhi Public School
Gomti Nagar Extension
Lucknow U.P.


(RUPAM SALUJA)
PRINCIPAL
DPS GOMTI NAGAR EXTN.
LUCKNOW

GEOGREEN TESTING LABORATORY

AN ISO 9001:2015, OHSAS : 2007 Certified Laboratory

Laboratory : C 1/20, Viraj Khand, Gomti Nagar Lucknow - 226010 (U.P.)

Phone : +91 9415215163, 9161202020 Email : geogreen.tl@gmail.com

Website : www.geogreen.in

TEST REPORT

(Water Sample Analysis)

Format No. GTL/SF/50

Sample Code No.	GTL/WS/0300	Report No.	WS12052025-0300
Sample Code Given By Client	Client	Issue Date	12/05/2025
Sample Drawn by	Client	Condition of the Sample	Sealed
Sample Drawn on	08/05/2025	Nature of Sample	Drinking Water
Sample Received on	08/05/2025	Test Duration	08/05/2025-12/05/2025
Sampling Location	At School	Sample	2 liter
Client's Name & Address	M/s Delhi Public School Sector-4, Gomti Nagar, Lucknow , Uttar Pradesh		

S. No.	Parameter Tested	Units	Result	Test Protocol Second Revision
1.	Color	Hazen	<5.0	APHA 2120 C,
2.	pH Value	-	7.32	APHA 4500- H+,B
3.	Turbidity	NTU	Nil	APHA 2130 B
4.	Electrical Conductivity	µs/cm	595.4	APHA 2510 B
5.	Total Suspended Solids	mg/L	Nil	APHA 2540 D
6.	Total Dissolve Solid	mg/L	300.0	APHA 2540 C
7.	Total hardness as CaCO ₃	mg/L	244.0	APHA 2340-C
8.	Calcium as Ca	mg/L	68.93	APHA 3500-Ca B
9.	Magnesium as Mg	mg/L	17.41	APHA 3500 B
10.	Alkalinity as CaCO ₃	mg/L	268.0	APHA 2320 B
11.	Chlorides as CL ⁻	mg/L	21.99	APHA 4500 CL ⁻ B
12.	Sulphate as So ₄ ^{- -}	mg/L	19.6	APHA 4500 -So ₄ ^{- -} E
13.	Nitrate as NO ₃	mg/L	11.3	IS 3025 (Part 34)
14.	Iron as Fe	mg/L	Nil	APHA 3500 Fe B
15.	Fluoride as F ⁻	mg/L	0.28	APHA 4500 F ⁻ D
16.	Sodium as Na	mg/L	17.8	APHA 3500 Na B
17.	Potassium as K	mg/L	13.3	APHA 3500 K , B
18.	Residual Free Chlorine	mg/L	BDL	APHA 2350 B

Page-1/1

Statement of conformity: The submitted sample conforms to Indian standard (10500:2012)/ 24rd EDITION APHA 2022parameters at sr. no.1 to 16, Applying decision rule based on guard band with 95% confidence level.

NOTE:


1. The results given above are related to the tested sample, for various parameters, as observed at the time of sampling. The customer asked for the above tests only.
2. This test report will not be used for any publicity/ legal purpose.
3. The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer.

End of Report

Prepared by

Review by

For Geogreen Testing Laboratory



Dr. Vijay Kumar Mishra
Quality Manager
(Authorized Signatory)

Manager
Delhi Public School
Gomti Nagar Extension
Lucknow U.P.

(RUPAM SALUJA)
PRINCIPAL
DPS GOMTI NAGAR EXTN.
LUCKNOW

GEOGREEN TESTING LABORATORY

AN ISO 9001:2015, OHSAS : 2007 Certified Laboratory

Laboratory : C 1/20, Viraj Khand, Gomti Nagar Lucknow - 226010 (U.P.)

Phone : +91 9415215163, 9161202020 Email : geogreen.tl@gmail.com

Website : www.geogreen.in

TEST REPORT

(Water Sample Analysis)

Sample Code No.	GTL/WS/0300	Report No.	WS12052025-0300
Sample Code Given By Client	Client	Issue Date	12/05/2025
Sample Drawn by	Client	Condition of the Sample	Sealed
Sample Drawn on	08/05/2025	Nature of Sample	Drinking Water
Sample Received on	08/05/2025	Test Duration	08/05/2025-12/05/2025
Sampling Location	At School	Sample	2 liter
Client's Name & Address	M/s Delhi Public School Sector-4, Gomti Nagar, Lucknow , Uttar Pradesh		

RESULTS

S. No.	Parameter Tested	Units	Result	Test Protocol
1.	Total Coliform	MPN/100ml	Absent	IS: 1622-1981
2.	Faecal Coliform	MPN/100ml	Absent	IS: 1622-1981

Page-1/1

- It is suitable for human consumption.
- The requirement mentioned here as per IS 10500: 2012 Drinking water specification
- Conformity statement: the sample complies to IS 10500: 2012 Drinking water specification with respect to above parameter tested.


End of Report

Prepared by

Review by

For Geogreen Testing Laboratory

Dr. Vijay Kumar Mishra
Quality Manager
(Authorized Signatory)



Manager
Delhi Public School
Gomti Nagar Extension
Lucknow U.P.

(RUPAM SALLUJA)
PRINCIPAL
DPS GOMTI NAGAR EXTN.
LUCKNOW